


T E S T C E R T I F I C A T E

ST-18-01-23-03

- Products:** Resilient floor coverings coated with "ESD Medi Coat"
- Manufacturer:** Dr. Schutz GmbH
Steinbrinksweg 30
31840 Hessisch Oldendorf
- Order:** Test of the electrostatic properties of a resilient floor with coverings coated with "ESD Medi Coat"
- Test methods:** Determination of different surface resistances and constant resistances of resilient floor according to DIN EN 61340-4-1, DIN EN 61340-4-5 (without Walking test), DIN EN 61340-2-3 and ANSI/ESD STM7.1, ANSI/ESD S4.1. Evaluation of the surface in EPA-areas according to DIN EN 61340-5-1/ ANSI S20.20 and TRGS 727 / IEC TS 60079-32-1:2013
- Test report:** No. 2716258_A1 / Part2 of 22 January 2018
- Test results:** The assessment according to DIN EN 61340-5-1/ ANSI S20.20 has shown that all limits were met. With the determined leakage resistance the requirements for the use in hazardous areas are fulfilled.

Dresden, 29 January 2018


Head of laboratory




Engineer in charge