

EINGELEGEN AM 02. JULI 2018



Entwicklungs- und Prüflabor Holztechnologie GmbH · Zellescher Weg 24 · 01217 Dresden · Germany

Dr. Schutz GmbH

Frau Bettina Schaar

Produktentwicklung/Anwendungstechnik

Arbeitssicherheit

Steinbrinkweg 30

31840 Hessisch Oldendorf

Entwicklungs- und Prüflabor  
Holztechnologie GmbH  
Zellescher Weg 24  
01217 Dresden

Tel.: +49 351 4662 0  
Fax: +49 351 4662 211  
info@eph-dresden.de  
www.eph-dresden.de

Dresden, 12 December 2017  
70-em/kle/bla

## Test Report Order No. 2716258 / Part 1

**Client:** Dr. Schutz GmbH  
Steinbrinksweg 30  
31840 Hessisch Oldendorf

**Date of order:** 13 September 2017

**Order:** Test of the electrostatic properties of a resilient floor with coverings  
coated with "ESD Top Coat"

**Contractor:** EPH – Laboratory Surface Testing

**Engineer in charge:** Dipl.-Ing. Detlef Kleber

Dr.-Ing. Rico Emmler

Head of Laboratory Surface Testing

The test report contains 9 pages. Any duplication, even in part, requires written permission of EPH.  
These test results are exclusively related to the tested material.

Managing Director:  
Dr.-Ing. Rico Emmler  
Dresden Local Court HRB 8072  
VAT Reg.No. DE 21 60 77 44 6

Commerzbank AG  
SWIFT: DRES DE FF 850  
IBAN: DE 13 8508 0000 0400 2982 00

ilac-MRA DAkkS  
Deutsche  
akkreditierter  
Prüfstelle  
DE 13 214 01 00

Deutsches  
Institut  
für  
Bautechnik  
Europäisch  
geprüfte Stelle für Bauprodukte 0766  
Bauaufsichtlich anerkannte Stelle des DIBt SAC 03

## 1 Task

The laboratory EPH was ordered by Dr. Schutz GmbH to determine different surface resistances and constant resistance of resilient floor with coverings coated with "ESD Top Coat" in a walking test according to DIN EN 61340-4-1, DIN EN 61340-4-5, DIN EN 61340-2-3 and ANSI/ESD STM7.1, ANSI/ESD S4.1. In addition, the suitability of the surface in ESA-areas should be tested according to DIN EN 61340-5-1/ ANSI S20.20 and explosive areas according to TRGS 727 or IEC TS 60079-32-1:2013.

## 2 Test Material

The client, Dr. Schutz GmbH, has sent 3 different samples of resilient floor with coverings coated with "ESD Top Coat" (thickness  $d = 2.5$  mm).

Sample		Description by the producer / article	Measurement position
A1	A1.1	ESD Top Coat, Sample1	left side
	A1.2		right side
A2	A2.1	ESD Top Coat, Sample 2	left side
	A2.2		right side
A3	-	ESD Top Coat, Sample 3	-

## 3 Requirements and measurement

### 3.1 Conditions for measurement

The test areas were conditioned 72 hours at drying atmosphere ( $23\text{ }^{\circ}\text{C} \pm 2\text{ K}$ ,  $12\% \pm 3\%$  relative air humidity) and were tested in the same climate

### 3.2 Measuring Instruments

The following resistance test devices were used: "PRS 801" (OF-27, fabricate PROSTAT) used measuring range  $1 \times 10^0 \dots 2 \times 10^{13}$  Ohm, measuring voltage 10 V and 100 V (measurement uncertainty < 5 %, lower than statistical variance of the measurement values).

### 3.3 Measurement setup

The following test was carried out according to different international norms:

Pos.	Properties	Measurement setup
1a	$R_{gp}$ resistance measured between an electrode placed on the surface of a test specimen and a groundable point fitted to the test specimen according to DIN EN 61340-4-1	
1b	$R_{gp}$ (surface-) resistance measured between an electrode placed on the surface of a test specimen and a groundable point fitted to the test specimen according to ANSI/ESD STM7.1	
2a	$R_{p-p}$ (surface-) resistance measured between two electrodes placed a specified distance apart on the same surface of a test specimen (distance d = 300 mm) according to DIN EN 61340-4-1	
3a	R <sub>g</sub> resistance measured between an electrode placed on the surface of a test specimen (hand electrode tester) and a local (earth-) ground according to DIN EN 61340-4-5 measurement according to ANSI/ ESD STM97.1 are equivalent, measured values can be transmitted/ transferred	
4a	Walking test according to DIN EN 61340-4-5 ( $U_p < 100 \text{ V}$ )	
4b	Walking test according to ANSI ESD STM97.2	

Pos.	Properties	Measurement setup
5a	$R_{p-p}$ (surface-) resistance measured between two electrodes placed a specified distance apart on the same surface of a test specimen (distance $d = 250$ mm) according to DIN EN 61340-2-3	
5b	$R_{p-p}$ (surface-) resistance measured between two electrodes placed a specified distance apart on the same surface of a test specimen according to ANSI/ESD STM7.1 in line with ANSI/ESD S4.1 (see pos.2.a)	

The leakage resistance shall refer to an point with earthing properties (see picture pos. 1a). For the determination of resistance, earthing points on the backside according to the norms were used. There were appropriated self-adhesive copper stripes electrodes, featuring resistance  $R < 0.001 \Omega$ . The  $R_{gp}$  resistance refer to the point to point resistance (e.g. electrode gap according to EN 61340-4-1,  $d = 300$  mm, see picture sample Pos. 2a). The  $R_g$  resistance refer to leakage resistance between a person body/ ESD (conducting) footwear and earthed floor covering. This resistance could be described as a system resistor (see picture pos. 3a).

The (yellow) electrode with a diameter of 65 mm and weight 2.5 kg was used for the examination according to DIN EN 61340-4-1. The (gray) electrode with a diameter of 63.5 mm and weight 2.27 kg was used for measurements according to DIN EN 61340-2-3, ANSI/ESD STM7.1 und ANSI/ESD S4.1. In addition, the resistor value  $R_x < 10^6 \Omega$  was measured at voltage  $U_M = 10$  V. Higher resistance values  $R_x > 10^6 \Omega$  were measured at voltage  $U_M = 100$  V.

## 4 Results

**Table 1:** Determined resistance values according to EN 61340-4-1

Measurement	A1		A2	
	$U_M = 10 \text{ V}; 100 \text{ V}$			
	$R_{gp}[\Omega]$	$R_{P-P}[\Omega]$	$R_{gp}[\Omega]$	$R_{P-P}[\Omega]$
1	1.80E+06	1.10E+07	1.00E+06	1.30E+07
2	1.10E+06	5.80E+06	1.20E+06	4.60E+06
3	1.40E+06	7.20E+06	1.60E+06	4.90E+06
4	1.20E+06	5.30E+06	1.40E+06	6.80E+06
5	3.40E+06	9.10E+06	1.90E+06	7.10E+06
6	1.80E+06	7.10E+06	1.70E+06	4.40E+06
geometric mean	<b>1.7E+06</b>	<b>7.4E+06</b>	<b>1.4E+06</b>	<b>6.3E+06</b>

**Table 2:** Determined leakage resistance (system resistor) according to EN 61340-4-5

Measurement	A1		A2			
	$U_M = 10 \text{ V}; 100 \text{ V}$					
	$R_g [\Omega]$					
1	5.40E+07		4.70E+07			
2	1.60E+08		5.40E+07			
3	1.40E+08		7.40E+07			
4	1.30E+08		6.60E+07			
5	1.20E+08		7.50E+07			
6	1.40E+08		8.70E+07			
arithmetic mean	1.24E+08		6.72E+07			
	<b>7.4E+07</b>					

**Table 3:** Determined resistance values according to EN 61340-2-3

Measur.	A1.1		A1.2		A2.1	
	$U_M = 10 \text{ V}; 100 \text{ V}$					
	$R_{gp}[\Omega]$	$R_{P-P}[\Omega]$	$R_{gp}[\Omega]$	$R_{P-P}[\Omega]$	$R_{gp}[\Omega]$	$R_{P-P}[\Omega]$
1	2.60E+05	9.30E+05	4.10E+05	1.50E+06	1.70E+06	5.70E+07
2	1.80E+05	1.40E+06	2.00E+05	1.30E+06	1.70E+06	6.30E+07
3	7.10E+05	8.10E+05	5.80E+05	1.40E+06	7.00E+07	1.30E+07
4	4.00E+05	1.30E+06	5.80E+05	1.20E+06	3.80E+06	4.20E+06
5	1.30E+06	1.30E+06	7.80E+05	1.60E+06	1.20E+06	2.80E+06
6	8.50E+05	1.10E+06	5.90E+05	1.40E+06	1.30E+06	2.40E+06
arithmetic mean	<b>6.2E+05</b>	<b>1.1E+06</b>	<b>5.2E+05</b>	<b>1.4E+06</b>	<b>3.3E+06</b>	<b>1.0E+07</b>

**Table 4:** Determined body voltage  $U_P$  [V] according to DIN EN 61340-4-5 sample A (A3)

Measurement/-points	body voltage $ U_{PI} $ [V]					
	1	2	3	1	2	3
	„sink value“			„crest value“		
AP 1	27	29	39	51	53	53
AP 2	26	28	36	45	52	53
AP 3	25	28	32	44	51	53
AP 4	24	27	28	44	50	53
AP 5	24	25	28	43	50	53
arithmetic mean (10V roundet)	30	30	30	50	50	50
Total arithmetic mean	30			50		

**Table 5:** Determined resistance values according to ANSI/ESD S7.1

Measurement $U_M = 10 \text{ V}; 100 \text{ V}$		A1.1	
		$U_M = 10 \text{ V}; 100 \text{ V}$	
		$R_{gp}/\Omega$	$R_{p-p}/\Omega$
earthing point X	1	6.2E+05	6.8E+05
	2	6.4E+05	8.8E+05
	3	8.5E+05	6.8E+05
	4	6.5E+05	9.4E+06
	5	7.3E+05	1.0E+06
	6	1.1E+06	1.7E+06
earthing point Y	1	1.1E+06	1.0E+06
	2	1.5E+06	8.2E+05
	3	3.1E+05	9.1E+05
	4	5.8E+05	8.4E+05
	5	7.6E+05	1.0E+06
	6	1.0E+06	1.4E+06
arithmetic mean		8.2E+05	1.7E+06
Median		7.5E+05	9.6E+05
Maximum		1.5E+06	9.4E+06
Minimum		3.1E+05	6.8E+05

**Table 6:** Determined resistance values according to ANSI/ESD S4.1 (Probe A 1.1)

Measure.	A1.1		A1.2		A2.1	
	U <sub>M</sub> = 10 V; 100 V					
	R <sub>gp</sub> [Ω]	R <sub>P-P</sub> [Ω]	R <sub>gp</sub> [Ω]	R <sub>P-P</sub> [Ω]	R <sub>gp</sub> [Ω]	R <sub>P-P</sub> [Ω]
X1	1.2E+06	1.7E+06	1.3E+06	1.7E+06	4.7E+05	9.5E+05
X2	7.4E+05	-	2.1E+05	-	8.2E+05	-
X3	4.6E+05	-	6.5E+05	-	8.8E+05	-
Y1	6.4E+05	1.0E+06	1.2E+06	7.6E+05	9.8E+05	1.1E+06
Y2	8.7E+05	-	8.7E+05	-	9.1E+05	-
Y3	4.5E+05	-	6.2E+05	-	7.7E+05	-
Median	6.9E+05	1.7E+06	7.6E+05	1.2E+06	8.5E+05	1.0E+06
Maximum	1.2E+06	1.7E+06	1.3E+06	1.7E+06	9.8E+05	1.1E+06
Minimum	4.5E+05	1.7E+06	2.1E+05	7.6E+05	4.7E+05	9.5E+05

**Table 7:** Determined body voltage  $U_p$  [V] according to ANSI/ESD STM97.2 sample A (A3)

## 5 Evaluation

The presented samples A were evaluated for the properties tested as follows:

### ESD-area: Sample A - ESD TopCoat

Pos.	Properties	Results	Requirement/Assessment according to EN 61340-5-1	
			23 °C und 12 % rel. Feuchte	Result
1a	Resistance $R_{gp}$ at the point with earthing properties according to EN 61340-4-1	$1.8 * 10^5 \Omega < R_{gp} < 8.5 * 10^6 \Omega$	$R_{gp} < 10^9 \Omega$	fulfill for floorings
2a	$R_{p-p}$ resistance between two points according to DIN EN 61340-4-1	$7.3 * 10^6 \Omega < R_{p-p} < 3.2 * 10^7 \Omega$	-	-
3a	Resistance $R_g$ according to EN 61340-4-5*	$R_g = 7.4 * 10^7 \Omega *$	$R_g < 10^9 \Omega$	fulfill for personnel grounding
4a	Body voltage according to EN 61340-4-5 (Up < 100 V)	$30 \text{ V} < U_M < 50 \text{ V}$	$U < 100 \text{ V}$	
5a	$R_{p-p}$ resistance between two points according to EN 61340-2-3	$5.2 * 10^5 \Omega < R_{gp} < 3.3 * 10^6 \Omega$ $1.1 * 10^6 \Omega < R_{p-p} < 1.0 * 10^7 \Omega$	$R_{gp} < 10^9 \Omega$ $R_{p-p} < 10^9 \Omega$	fulfill for work surfaces/ storage racks

Pos.	Properties	Results	Requirement/Assessment according to ANSI S20.20	
1b	Resistance $R_{gp}$ at the point with earthing properties according to ANSI/ESD STM7.1	$3.1 * 10^5 \Omega < R_{gp} < 1.6 * 10^6 \Omega$	$R_{gp} < 10^9 \Omega$	fulfill for floorings
2b	Surface resistance $R_{p-p}$ between two points according to ANSI/ESD STM7.1	$6.8 * 10^5 \Omega < R_{p-p} < 9.4 * 10^6 \Omega$	-	-
3b	System resistance $R_g$ according to ANSI/ESD STM97.1	$R_g = 7.4 * 10^7 \Omega *$	$R_g < 10^9 \Omega$	fulfill for personnel grounding
4b	Body voltage according to ANSI/ESD STM97.2	$23 \text{ V} < U_M < 37 \text{ V}$	$U < 100 \text{ V}$	
5b	Resistance $R_{p-p}$ according to ANSI/ESD S4.1	$2.1 * 10^5 \Omega < R_{gp} < 1.3 * 10^6 \Omega$ $1.0 * 10^6 \Omega < R_{p-p} < 1.7 * 10^6 \Omega$	$R_{gp} < 10^9 \Omega$ $R_{p-p} < 10^9 \Omega$	fulfill for work surfaces/ storage racks

\* measurement according to ANSI/ ESD STM97.1 are equivalent , measured values can be transmitted/ transferred

### Note explosion protection

In potentially explosive atmospheres requirement for floorings are described in "Technical Rules for Hazardous Substances" national standard (TRGS 727:2016; Germany) and international norm (IEC TS 60079-32-1:2013). Both regulations require for conductive resistance a value  $R_E < 10^8 \Omega$ . The required leakage resistance corresponds to the resistance  $R_{gp}$  of the presented samples to a point with earthing properties (see sample A:  $R_{gp\max} < 2.5 * 10^6 \Omega$  - Table 2). The value determined at sample A fulfils this requirement. The test samples of resilient floor coverings coated with "ESD Top Coat", which have been reported, are approved to be suitable for hazardous areas.



Dipl.-Ing. Detlef Kleber  
Engineer in charge